



Cullman Electric Cooperative Member Requirements / Responsibilities Underground Service

There are requirements/ responsibilities, which the member must be aware of and meet for underground service. They are as follows:

1. An underground meter base must be installed by the member and must be suitable for 3-inch conduit
2. Service is not considered ready for connection or for the ditch to be dug until the meter base has been installed and entrance cable or wire has been connected from the meter base to the main disconnect. The member will need to contact Cullman EC when ready.
3. The member will be required to provide a clear path from the service pole to the meter base.
4. The member will be responsible for notifying, marking and exposing all obstacles that may be in the way of the installation process. (Example: septic tanks, field lines, water lines, gas lines, etc.)
5. The member will be responsible for any damage incurred due to the improper notification or marking of obstacles identified in part 4 of these requirements.
6. The member will be responsible for any additional aid-to-construction cost incurred as a result of the obstacles, or similar unforeseen obstacles, as described above which may result in both the delay and increased cost of installation of any underground facilities. (Example: rocks, driveways, roads, trees, dirt mounds, etc.)
7. The member will be responsible for removing the necessary portion of concrete foundation immediately below the meter base.
8. The member must install ground rod 18 to 24 inches to one side of the meter base.
9. The member will be responsible for signing this form stating he/she is aware of these requirements and that he/she received a copy of this form.
10. The member will be responsible for any damage of the meter base or conduit after installation. Example: damage due to landscaping or over compaction of trench.)

Cullman Electric Cooperative

Account Number _____

Employee

Member

Date

Date