



NOTES

1. THE METER CENTER SHALL BE FURNISHED AND MAINTAINED BY MEMBER; OBTAIN APPROVAL FROM CO-OP PRIOR TO PURCHASE.
2. EQUIPMENT MUST BE PROPERLY GROUNDED AS REQUIRED BY THE NATIONAL ELECTRICAL CODE, LATEST REVISION.
3. THE METER CENTER MUST BE MOUNTED ON THE EXTERIOR OF THE BUILDING. A CLEAR WORK AREA WITH AN 18" CLEARANCE ON ALL SIDES AND A 36" CLEARANCE IN FRONT OF METER BASE IS REQUIRED. THIS CLEARANCE MUST EXTEND TO A HEIGHT OF 84".
4. LIGHTNING ARRESTER TO BE INSTALLED AND MAINTAINED BY MEMBER. (RECOMMENDED)
5. THE NUMBER OF METER POSITIONS MAY VARY.
6. EACH SOCKET POSITION MUST BE CLEARLY AND PERMANENTLY IDENTIFIED AS TO UNIT SERVED. (NEC 230.70(b))
7. MEMBER IS RESPONSIBLE FOR TERMINATION OF SECONDARY CABLE IN METER/SWITCHGEAR.
8. ANTIOXIDANT COMPOUND IS REQUIRED ON ALL CONNECTIONS TO ALUMINUM CONDUCTORS.
9. MEMBER IS SOLELY RESPONSIBLE FOR IDENTIFYING OR LOCATING ALL BELOW GRADE FACILITIES NEAR THE EXCAVATION OF THE SERVICE CABLE INCLUDING, BUT NOT LIMITED TO, ELECTRIC CONDUCTORS, COMMUNICATION LINES, WATER LINES, SEWER LINES, DRAIN FIELDS, SEPTIC TANKS, ETC. (IF APPLICABLE).

			DATE: 2-11-05	GROUPED / GANGABLE METER CENTER	SPEC. NO. APT-2
			DRAWN BY: S.T.W		
			APP'D BY:		
NO.	REVISION	DATE		 STANDARD ELECTRIC SERVICE REQUIREMENTS CULLMAN ELECTRIC COOPERATIVE CULLMAN, ALABAMA	