



NOTES

1. TO MAINTAIN 16'-0" CLEARANCE OVER DRIVEWAYS, A MOUNTING HEIGHT OF 17'-0" IS REQUIRED FOR A 4/0 QUADRAPLEX SERVICE, WITH A SPAN LENGTH OF 100'-0". FOR OTHER SPAN LENGTHS OR CONDUCTOR SIZES CONTACT CO-OP FOR MOUNTING HEIGHT.
2. CO-OP SHALL SPECIFY LOCATION OF SERVICE ATTACHMENT AND METER SOCKET.
3. METER MUST BE READILY ACCESSIBLE WITH NO OBSTRUCTIONS. A CLEAR WORK AREA WITH AN 18" CLEARANCE ON ALL SIDES AND A 36" CLEARANCE IN FRONT OF METER BASE IS REQUIRED. THIS CLEARANCE MUST EXTEND TO A HEIGHT OF 84".
4. FOR SERVICES 600 AMPS AND UNDER, A SELF-CONTAINED METER SOCKET WILL BE USED.

			DATE: 2-11-05	SMALL COMMERCIAL OVERHEAD SERVICE (LESS THAN 600 AMPS) WALL MOUNTED	SPEC. NO. OH-5
			DRAWN BY: S.T.W		
			APP'D BY:		
NO.	REVISION	DATE		 STANDARD ELECTRIC SERVICE REQUIREMENTS CULLMAN ELECTRIC COOPERATIVE CULLMAN, ALABAMA	